

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 23/04/26

It is certified that an inspection team headed by Junior Engg.

(Name of Officers with designation) from Harish Sharma, J.E. PHED

inspected the SANSKARAM PUBLIC SCHOOL, KNATWAS

(Name & Address of the school) on 18/03/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. S51860 dated 29/03/26

of Jhajjar Distt. Lab. (PHED Lab) certified that

the SANSKARAM PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institutor. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 22/04/27

Signature with Seal: Sub Divisional Engineer

Name: Public Health Engineering

Designation: Sub Division No. 2, Jhajjar

Name & Address of the Office / Department :

To SANSKARAM PUBLIC SCHOOL
KNATWAS, JHAJJAR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Memo No:- 400

Date:- 24/03/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : JJR/07795/3/2026 / Private	Sample Details	Date & Time
Sender : SANSKARAM PUBLIC SCHOOL , KHATIWAS	Collected By	SANSKARAM PUBL...
Location : , SANSKARAM PUBLIC SCHOOL, KHATIWAS	Collection Date	16/03/2026 at 09:16
Sample Description : Drinking Water	Received at lab	19/03/2026 at 12:22
Latitude / Longitude : 76.589288 / 28.629253	Analysis Start Date	19/03/2026
	Analysis End Date	19/03/2026
	Sample Quantity	2 Litre

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.24	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	1	5 Hazen Units	15 Hazen Units	IS 3025 Part 4: 2021 /APHA 24th Edition -2120 B
5	Total Dissolved Solids @ 180°C ± 2°C	70	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	16.00	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	4.28	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	1.30	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	23.00	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	5.53	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	12.78	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO4-E
12	Fluoride as F	0.09	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition 4500 F-D:
13	Iron as Fe	0.12	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate as No3	3.48	45 mg/lit.	45 mg/lit.	APHA 4500-NO3- B / USEPA
15	pH @ 25°C	7.04	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED JHAJJAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

SONIA ,CHEMIST
DISTRICT WATER TESTING LABORATORY ,JHAJJAR
email:-chemist.jhajjar@phedharyana.gov.in